

**To:** McCoy, Erin[McCoy.Erin@epa.gov]; Jackson, Hylton [DNR][Hylton.Jackson@dnr.iowa.gov]; Woodruff@dmwww.com[Woodruff@dmwww.com]; Gazi George (gttsi2000@yahoo.com)[gttsi2000@yahoo.com]  
**From:** Mills, Brian (Safety)  
**Sent:** Mon 8/22/2016 3:49:32 PM  
**Subject:** Dico Groundwater Extraction and Treatment System Back in Operation

Please be notified that the groundwater extraction and treatment system was repaired and back in operation at approximately 9:45 AM today.

Troubleshooting by the contractor revealed that the electrical phase monitor inside the control panel was bad. The bad electrical phase monitor was replaced with a new one and the groundwater extraction and treatment system was restarted.

Please Note: The information contained in this message may be privileged and confidential, protected from disclosure, and/or intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, distribution, copying or other dissemination of this communication is strictly prohibited. If you received this communication in error, please immediately reply to the sender, delete the message and destroy all copies of it. Any views or opinions expressed in this message are solely those of the individual sender, except where the sender specifies with authority them to be the views of Titan. Titan reserves the right to monitor both incoming and outgoing e-mails and therefore the sender and recipient of such e-mails should have no expectation of privacy in this regard. Thank You.